

# SPECIALIZED PUMP COMPANY, INC.

"IN BUSINESS SINCE 1972"

P.O. Box 3805 HOLLYWOOD, FLORIDA 33083 PHONE (954) 967-2071 FAX (954) 967-2074

WWW.SPECIALIZEDPUMP.COM

**PIPE GROMMET DETAIL**

**DISCHARGE/VENT CROSS SECTION DETAIL**

**10" DIA. INSPECTION PLATE:**  
THIS PLATE CAN BE TAPPED TO ACCEPT MFS CORD GRIPS. SEE 420A-002.

**NOTES:**

- COVER SHALL BE PAINTED WITH INDUSTRIAL GRADE POLYURETHANE ENAMEL.
- PUMP COVER PLATES AND INSPECTION PLATE SHALL BE 1/4" THICK STEEL.

DIMENSIONAL DATA							
For Basin Dia. "A"	"B"	Cover Thickness "C"	"D"	"E"	"F"	"G"	"H"
30"	36"	1/4"	32 1/2"	14"	16"	1 1/4", 1 1/2", 2", 3", 4"	1 1/4", 1 1/2", 2", 3", 4"
36"	42"	1/4"	38 1/2"	16"	18"	1 1/4", 1 1/2", 2", 3", 4"	1 1/4", 1 1/2", 2", 3", 4"
42"	48"	1/4"	44 1/2"	20"	22"	1 1/4", 1 1/2", 2", 3", 4"	1 1/4", 1 1/2", 2", 3", 4"
48"	54"	1/4"	51"	20"	22"	1 1/4", 1 1/2", 2", 3", 4"	1 1/4", 1 1/2", 2", 3", 4"
54"	60"	3/8"	57"	26"	28"	1 1/4", 1 1/2", 2", 3", 4"	1 1/4", 1 1/2", 2", 3", 4"
60"	66"	3/8"	63"	26"	28"	1 1/4", 1 1/2", 2", 3", 4"	1 1/4", 1 1/2", 2", 3", 4"
72"	78"	3/8"	75"	26"	28"	1 1/4", 1 1/2", 2", 3", 4"	1 1/4", 1 1/2", 2", 3", 4"

<b>SPECIALIZED PUMP CO., INC.</b>	<b>TITLE</b> DUPLEX STEEL PUMP COVER	
	<b>PROJECT</b>	<b>JOB NO.</b>
	<b>CUSTOMER</b>	<b>P.O. NO.</b>
		<b>DWG. NO.</b> SC10408